

Water-Sewer Committee Meeting

11-4-24

6:30pm

Members in Attendance

Mayor Stan Darter

Aldersperson Tina Charron

Alderman Kyle Buettner

Alderman Russ Row

Alderman Gary Most

Alderman Jim Hopkins

Alderman Jim Trantham

Alderman Joel Vogt

Alderman Matt Buettner

Michelle Childers

Nate Krebel

Tim Birk

JR Landeck

Dennis Brand

Jeff Davis

Alex Bishop

1. Petitions By Citizens on Non-Agenda Items – none
2. Approval of 10-28-24 Water-Sewer Cmte Mtg Minutes – Motion to approve made by Alderman Russ Row – Seconded by Joel Vogt – All in favor – Minutes Approved
3. Water Plant Update – Pressure test has not been completed yet, hopefully in the next week. Potable Water at the Clear Well, while testing the reactors there was a small amount of sediment found. They are going to flush them and see if that takes care of the issue.
4. Sewer Plant Blowers need to be replaced, leaking oil. Ten-week lead time, five blowers in total but one needs to be replaced as soon as possible. \$22,000 per blower, Motion Made by Joel Vogt to order one Blower, Seconded by Alderman Jim Hopkins. All in favor, motion passes.
5. Comments – Shawn Kennedy mentioned that a Sewer Scata System invoice was lost in the mail. They ran a new check and it was picked up in person.

Motion made to Adjourn by Alderman Russ Row Seconded by Alderman Joel Vogt. All in favor, meeting adjourned at 6:52pm